



Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received

Code 61.5-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title Indiana Residential Code		Edition 2009
Section number and title E3604		Page 659
Proponent Charlie Eldridge	Title Consultant	
Address 551 Grassy Ln., Indianapolis, IN 46217		Phone (317) 370-3444
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
SECTION E3604 <u>NON-UTILITY INSTALLED</u> OVERHEAD SERVICE-DROP AND SERVICE CONDUCTORS <u>INSTALLATION</u>		
REASON AND FISCAL IMPACT		
<p>The rules for services are different for service drops installed by electric utilities and electrical contractors. The drawing below illustrates a little of the differences. Clearances are another big difference. An open wire service drop over a back yard is generally required to have 12 ½' of clearance while the IRC only requires 10' for the same service drop.</p> <p>Drop 18'' Min over roof inside 6' radius</p> <p>Top view of roof</p> <p>4' Max</p> <p>18'' Min</p> <p>6' Max Over Roof</p> <p>NEC</p> <p>NESC</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		